

Building Regulations Part L 2013 Wales Wider Engagement Event


Approach to Cost Modelling

Jim Proctor

Energy Team, Davis Langdon, an AECOM Company

Reminder of Carbon Abatement Cost Curve Built up element by element

5 Star Hotel



Base Cost Plans

Base cost plans for each building type to Building Regulations 2010

- Primary school, 3,043m²
- Community hospital, 2,128m²
- Hotel, 1,459m²
- Naturally ventilated office, 919m²
- Supermarket, 1,248m²
- Warehouse, 5,322m²
- Nursing home, 1,935m²

Cost data from Davis Langdon Cardiff office and in-house benchmark data adjusted for Wales

Extra Over costs

- Extra over costs of improving the key parameters to fabric and services modelled (using in house data and talking to directly to manufacturer's where necessary)

- Extra over costs of plant and equipment replacement and annual maintenance over a 60 year period modelled (using in house data from our FM team, published guidelines and discussions direct with manufacturers where necessary)

Extra over costs – Community Hospital

Fabric Measures

| | | Capital | Maintenance | Life Expectancy |
|--------------------------------|------------|--------------|-------------|-----------------|
| | Element | £/m2 Element | £ | Year |
| Floor U-value W/m2.K | Floor-0.25 | 0.0 | 0 | 60 |
| | Floor-0.20 | 5.5 | 0 | 60 |
| | Floor-0.15 | 10.2 | 0 | 60 |
| | Floor-0.10 | 15.73 | 0 | 60 |
| Roof U-value W/m2.K | Roof-0.25 | 0.0 | 0 | 60 |
| | Roof-0.20 | 5.34 | 0 | 60 |
| | Roof-0.15 | 8.01 | 0 | 60 |
| | Roof-0.10 | 9.79 | 0 | 60 |
| Wall U-value W/m2.K | Wall-0.35 | 0.0 | 0 | 60 |
| | Wall-0.25 | 9.77 | 0 | 60 |
| | Wall-0.20 | 14.32 | 0 | 60 |
| | Wall-0.15 | 20.56 | 0 | 60 |
| Window U-value W/m2.K | Window-2.0 | 0.0 | 0 | 60 |
| | Window-1.6 | 22.35 | 0 | 60 |
| | Window-1.3 | 73.4 | 0 | 60 |
| | Window-0.9 | 121.17 | 0 | 60 |
| Air permeability m3/m2/hour | AP-10 | 0.0 | 0 | 60 |
| | AP-7.5 | 0.0 | 0 | 60 |
| | AP-5 | 1.25 | 0 | 60 |
| | AP-3 | 1.88 | 0 | 60 |

Extra over costs – Community Hospital Building Services Measures

| | Element | Capital | Maintenance | Life Expectancy |
|---|------------------|-----------|--------------|-----------------|
| | | £/m2 GIFA | £ | Years |
| Luminaire efficiency Luminaire lumens / watt | Lighting-55lm | 0.0 | Under review | 20 |
| | Lighting-65lm | 2.12 | Under review | 20 |
| Lighting Occupancy Control | Lighting-Occ-No | 0.0 | Under review | 15/20 |
| | Lighting-Occ-Yes | 5-10 | Under review | 15/20 |
| Lighting Daylight Control | Lighting-Day-No | 0.0 | Under review | 15/20 |
| | Lighting-Day-Yes | 5-10 | Under review | 15/20 |
| Boiler Efficiency | Heating-0.84 | 0.0 | Under review | 15 |
| | Heating-0.86 | 0.38 | Under review | 15 |
| | Heating-0.88 | 0.65 | Under review | 15 |
| | Heating-0.91 | 0.94 | Under review | 15 |
| Heat recovery Yes (70%) / No | Heat-Rec-0 | 0.0 | Under review | 20 |
| | Heat-Rec-0.7 | 6.72 | Under review | 20 |
| Cooling SEER | Cooling-2.5 | 0.0 | Under review | 20 |
| | Cooling-3 | 2.47 | Under review | 20 |
| | Cooling-3.5 | 3.62 | Under review | 20 |
| | Cooling-4 | 5.0 | Under review | 20 |
| Central AHU Specific Fan Power w/l/s | SFP-2.2 | 0.0 | Under review | 20 |
| | SFP-2.0 | 0.6 | Under review | 20 |
| | SFP-1.8 | 2.25 | Under review | 20 |
| Terminal Unit Specific Fan Power w/l/s | TUSFP-0.8 | 0.0 | Under review | 15 |
| | TUSFP-0.5 | 4.2 | Under review | 15 |
| | TUSFP-0.3 | 6.0 | Under review | 15 |

Consistency of Cost

Costs of increasing efficiencies of some of the services elements (most notably those below) vary between manufacturer's and their product ranges, and need to be carefully considered in order to provide a representative view when looking at the step increases in efficiencies

- Lighting
- Boilers
- Chillers
- AHU & terminal unit SFP

Low and Zero Carbon Technologies

Technologies being considered, including the effect of learning rates:

- Solar PV
- Solar Thermal
- Gas CHP (CCHP in the case of the hospital)
- Wind Power (although limited by location)

Use of Welsh specific costs for LZC technologies or are these similar to England.....this depends on the size and scale of the installation, which may affect the materials and labour costs.

Discussions with local suppliers and installers to establish the effect of this.

Low and Zero Carbon Technologies- Typical Base costs (£/unit varies), 2010 and Learning Rates (under review)

| | per kW(e) | per m2 | per m2 | per kW |
|------|-----------|---------------|----------|--------|
| Size | Gas CHP | Solar Thermal | Solar PV | Wind |
| 0.6 | 3289 | 1505 | 1750 | 13542 |
| 2.5 | 3289 | 744 | 775 | 5573 |
| 5 | 3289 | 583 | 552 | 4792 |
| 6 | 3289 | 513 | 534 | 4010 |
| 10 | 3289 | 513 | 534 | 3490 |
| 15 | 3289 | 513 | 517 | 2917 |
| 20 | 3289 | 513 | 517 | 2917 |
| 30 | 3289 | 513 | 517 | 2917 |
| 40 | 2741 | 507 | 517 | 2917 |
| 50 | 2193 | 507 | 400 | 2917 |
| 60 | 1974 | 507 | 400 | 2917 |
| 70 | 1645 | 507 | 390 | 2917 |
| 80 | 1425 | 507 | 390 | 2917 |
| 90 | 1316 | 507 | 380 | 2917 |
| 100 | 1206 | 507 | 380 | 2917 |
| 110 | 1206 | 507 | 370 | 2917 |
| 120 | 1096 | 507 | 370 | 2917 |
| 130 | 1096 | 507 | 370 | 2917 |
| 140 | 987 | 507 | 360 | 2917 |
| 150 | 987 | 507 | 360 | 2396 |
| 160 | 987 | 507 | 360 | 2396 |
| 170 | 987 | 507 | 350 | 2396 |
| 180 | 987 | 507 | 350 | 2396 |
| 190 | 877 | 507 | 350 | 2396 |
| 200 | 877 | 507 | 350 | 2396 |

| | Gas CHP | Solar Thermal | Solar PV | Wind |
|------|---------|---------------|----------|------|
| 2008 | 100% | 100% | 100% | 100% |
| 2009 | 100% | 100% | 100% | 99% |
| 2010 | 100% | 100% | 100% | 97% |
| 2011 | 91% | 100% | 83% | 96% |
| 2012 | 87% | 100% | 75% | 95% |
| 2013 | 83% | 98% | 69% | 94% |
| 2014 | 80% | 93% | 63% | 93% |
| 2015 | 78% | 91% | 60% | 92% |
| 2016 | 76% | 89% | 57% | 91% |
| 2017 | 75% | 87% | 56% | 90% |
| 2018 | 73% | 86% | 53% | 89% |
| 2019 | 72% | 85% | 51% | 89% |
| 2020 | 70% | 84% | 50% | 88% |
| 2021 | 69% | 84% | 49% | 87% |
| 2022 | 68% | 83% | 48% | 86% |
| 2023 | 67% | 82% | 47% | 86% |
| 2024 | 65% | 82% | 45% | 85% |
| 2025 | 64% | 81% | 44% | 84% |